

Silent Gliss Fabrics&Components GmbH
Rebgartenweg 5
79576 Weil am Rhein
GERMANY

Your message - reference

-

our reference

PW/1120

Gent

2017-07-13

Certification report 17/1120

1. Description of the flooring:

Product	Sunscreen made of on 3µm thick alu support and a 65%PVC/35%PES surface
Mass	325 g/m ²
Thickness	0,45 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009) based on:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee

Silent Gliss Fabrics&Components

our reference

PW/1120

Gent

2017-07-10

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

C – s2, d0

Mechanically fixed and free hanging over a 13 mm thick plasterboard (700 kg/m³ or more) and all substrates classified A1 and A2-s1,d0 which density is superior to 525 kg/m³

Related commercial names to this product group	Aluscreen Futura
The obtained classification is based on the next test reports	CTB 17.01728.01
Validity of the certificate	18/06/2022

Petra Wittevrongel

Product Certifier